

## Far-UVC: Technology Update with an Untapped Potential to Mitigate Airborne Infections

P. Jacob Bueno de Mesquita<sup>1\*</sup>, Rosemary K. Sokas<sup>2</sup>, Mary B. Rice<sup>3</sup>, Edward A. Nardell<sup>4</sup>

<sup>1</sup> Sustainable Energy and Environmental Systems, Lawrence Berkeley National Laboratory, Berkeley, CA, USA, 94720

<sup>2</sup> Georgetown University School of Health, Department of Human Science, Washington, DC, USA

<sup>3</sup> Beth Israel Deaconess Medical Center, Division of Pulmonary, Critical Care and Sleep Medicine, Boston, MA, USA

<sup>4</sup> Harvard Medical School, Boston, MA, USA

\* Corresponding author

Clinicians and patients spent the fall and winter of 2022 grappling with the triple surge of SARS-CoV-2, influenza, and RSV. Meanwhile, a host of zoonotic diseases await the inevitable mutations that could fuel human-to-human transmission and the next pandemic. Because respiratory infections are transmitted through shared indoor air, strategies for prevention should embrace the effective modalities for cleaning indoor air. As an analogy, we don't rely on vaccines to prevent waterborne illness, even though there is a vaccine against cholera - we rely on effective water treatment to provide safe drinking water free of the spectrum of disease-causing microbial agents. We should take a similar engineering approach to shared indoor air spaces.

Existing technologies include air filtration, ventilation, and application of Ultraviolet Germicidal Irradiation, UVGI, now called Germicidal Ultraviolet, GUV. These modalities have a proven track record for safely reducing airborne pathogen exposure, with benefits that complement and are of similar magnitude as masking and vaccination (1-2). An air change (AC) occurs when the volume of outdoor, infection-free outdoor enters and leaves a room. A common measure of ventilation is air changes per hour (ACH). Because new and old air mix, one AC removes about 63% of room air contaminants. An *equivalent* air change (eAC) due to GUV or filtration represents the inactivation or removal of 63% of pathogens from a room, and equivalent air exchanges per hour (eACH) standardize the rate of air cleaning by either ventilation, filtration, or GUV. GUV can reduce pathogens as measured by eACH more effectively than ventilation and filtration, because these depend on dilution with outside air.

Since its inception nearly a century ago, UVC at a wavelength of 254 nm has been used and is recommended by CDC to reduce airborne pathogen transmission in hospitals, schools, and homeless shelters (3-5). Newer LED GUV (currently 265-70 nm) will eventually replace mercury 254 nm sources.

However, sources of 254 and 265-70 nm GUV must be kept overhead to avoid direct overexposure resulting in short term keratoconjunctivitis and erythema (6). Although UVA and UVB in sunlight are recognized causes of cataracts and skin cancer, UVC, with shorter wavelengths and higher energy is so biologically active that it is mostly absorbed before reaching the lens or the deep basal layer of skin (where skin cancers originate). The technological breakthrough of even shorter wavelength, or “far”-UVC (222 nm), is yet more biologically active, and absorbed in the tear layer of the eye or the stratum corneum of the skin, theoretically eliminating even short-term adverse effects. This allows use of far-UVC directly into occupied spaces, offering more efficient air disinfection where people breathe, speak, and cough (Figure 1).

In the laboratory, 222 nm UVC is as effective a germicide as 254 nm GUV – including against *M. tuberculosis*, SARS-CoV-2 and influenza (7). A single, upper-room GUV fixture delivered the equivalent of 18-110 eACH, depending on the susceptibility of the test microbe and relative humidity (3), whereas a single far-UVC fixture delivered 33-66 eACH (8). Even the lower range of effectiveness with more robust pathogens corresponds to more efficient air cleaning than is feasible with ventilation and filtration.

Compared with 254 nm, 222 nm far-UVC inactivates viral aerosols through a dual mechanism that damages protein and nucleic acid structures, suggesting the potential for improved disinfection effectiveness of 222 nm far-UVC over both 254 and 265-270 nm systems. Far-UVC can be applied across a broader range of indoor settings and closer to breathing zones, making them potentially useful in public transportation and other settings while offering better protection from infectious transmission from nearby room occupants.

Effective, energy efficient air disinfection is a critical public health need. The three available technologies – ventilation, filtration, and GUV – vary greatly in their practical capacity to interrupt airborne transmission of pathogens. Ventilation and filtration improve air quality and offer some protection against infection, but in many scenarios may not produce sufficient levels of equivalent ventilation to reduce transmission (9,10). GUV (whether upper-room 254 nm or far-UVC 222 nm) provides the high eACH range needed to address airborne pathogens that are shed at high quanta emissions rates (e.g., 5,000 quanta per hour for measles or 1,000 quanta per hour for SARS-CoV-2 (9)). Increased air disinfection with GUV reduces the inhalation exposure to infectious aerosols and the risk of infection and, potentially, the severity of infections that do occur (11). Although well-functioning HVAC systems are essential, GUV provides enhanced protection at sustainable cost (12) (13).

Laboratory toxicology studies have consistently demonstrated the safety of properly filtered 222 nm GUV. Highly susceptible hairless mice exposed to far-UVC for 8 hours a day, 5 days a week, for 66 weeks (considered *long-term exposure* for mouse studies) did not develop skin abnormalities any more frequently than unexposed mice or those exposed to lower doses (14). After repetitive high dose exposure to 222 nm UVC, hairless mice susceptible to skin cancer due to xeroderma pigmentosum knockout developed few DNA dimers in the upper epidermis, no elevation in the chemokine CXCL1 involved in carcinogenesis, no ear swelling, no corneal damage, no tumor formation, while mice exposed to lower doses of 254-nm UVC or UVB developed elevated markers of inflammation and carcinogenesis and tumors (15). Studies exposing human skin models or human volunteer skin showed similarly low cytotoxicity (16-17). Studies examining skin and eye effects across age groups and in those with sensitive skin or dry eyes found no significant difference in susceptibility to any potential adverse health effects from far-UVC exposure (18).

Other health and environmental concerns have been raised about 222 nm GUV, including the potential generation of ozone or other inhalational toxicants. Investigation of photochemistry found that 222 nm use could lead to the formation of ozone, radicals, volatile organic compounds, and secondary organic particulates, emphasizing the importance of maintaining ventilation standards to remove typical levels of indoor and outdoor air contaminants (19). Thus far, secondary chemistry studies are limited to highly controlled chamber studies. Real world measurements under different use scenarios coupled with assessment of health outcomes would provide useful information to confirm the findings of the controlled studies and determine the magnitude of ozone and secondary toxicant generation.

Concerns have been raised about eliminating inhalational infections in young children, potentially making them more immunologically susceptible to later infections and asthma. Research can be carried out to test this variant of the hygiene hypothesis, but the close contact among young children in daycare, school and other settings makes elimination of viral transmission unlikely. Reducing exposure to rhinovirus in early life may help prevent viral infection-associated asthma exacerbations at school age (20). Concerns have also been raised about altering the skin microbiome via far-UVC. However, only a fraction of skin is exposed to GUV when used in indoor environments and the microbial disruption is likely far less than the impact of bathing.

The safety profile of properly filtered 222 nm GUV is encouraging and widespread application in indoor spaces would reduce infection risk. Priority spaces for application include congregate settings like healthcare, schools, grocery stores, public transportation, restaurants, bars, and occupational settings that place workers in proximity with each other or the public. Guidelines on the application of upper room GUV exist and new guidelines are expected soon from ASHRAE. Although 222 nm GUV is widely in use, formal application guidelines are not yet available.

The following research and development should be prioritized:

- Engineering and manufacturing research to improve availability and reduce costs
- Post-installation dynamic dose monitoring with UV-sensitive film badges,
- Field condition active surveys for skin and eye complaints,
- In use room chemistry studies,
- Ongoing clinical studies to address intervention effectiveness as well as any associated adverse outcomes,
- Public communication and engagement research to better promote correct, widespread adoption.

The emergence of far-UVC offers a game-changing approach to controlling community transmission of airborne infections in shared indoor settings. Environmental control of airborne pathogens provides widespread population benefit against a variety of respiratory infections responsible for millions of deaths per year. We advocate for a greater level of investment in GUV, far-UVC in particular, and a sense of urgency. While COVID-19 is no longer a WHO global health emergency of Public Concern as of May 2023, the infection and other airborne viruses continue to spread, and other pandemics will follow.

## References


1. Kwan A, Sears D, Bertozzi SM, Williams B, CalPROTECT Project Group. California State Prisons During the COVID-19 Pandemic. A Report by the CalPROTECT Project [Internet]. CalPROTECT Project (California Prison Roadmap for Targeting Efforts to Address the Ecosystem of COVID Transmission); 2022 May [cited 2022 May 27]. Available from: <https://amend.us/wp-content/uploads/2022/05/2022-0501-CalPROTECT-Report.pdf>
2. Nealon J, Mefsin Y, McMenamin M, Ainslie KEC, Cowling BJ. Reported Effectiveness of COVID-19 Booster Vaccines: A Systematic Review of Early Literature and Implications for Emerging Vaccination Policy [Internet]. Rochester, NY; 2022 [cited 2023 May 9]. Available from: <https://papers.ssrn.com/abstract=4130010>
3. McDevitt JJ, Milton DK, Rudnick SN, First MW. Inactivation of poxviruses by upper-room UVC light in a simulated hospital room environment. *PloS One*. 2008;3(9):e3186.
4. Mphahlele M, Dharmadhikari AS, Jensen PA, Rudnick SN, van Reenen TH, Pagano MA, et al. Institutional Tuberculosis Transmission. Controlled Trial of Upper Room Ultraviolet Air Disinfection: A Basis for New Dosing Guidelines. *Am J Respir Crit Care Med*. 2015 Aug 15;192(4):477–84.
5. Wells MW, Holla WA. Ventilation in the flow of measles and chickenpox through a community. *J Am Med Assoc*. 1950 Apr 29;142(17):1337–44.
6. International Commission on Illumination, editor. UV-C photocarcinogenesis risks from germicidal lamps: technical report. Vienna: CIE Central Bureau; 2010. 15 p. (CIE publications).
7. Welch D, Buonanno M, Buchan AG, Yang L, Atkinson KD, Shuryak I, et al. Inactivation Rates for Airborne Human Coronavirus by Low Doses of 222 nm Far-UVC Radiation. *Viruses*. 2022 Mar 25;14(4):684.

8. Eadie E, Hiwar W, Fletcher L, Tidswell E, O'Mahoney P, Buonanno M, et al. Far-UVC (222 nm) efficiently inactivates an airborne pathogen in a room-sized chamber. *Sci Rep*. 2022 Mar 23;12(1):4373.
9. Bueno de Mesquita PJ. Airborne Transmission and Control of Influenza and Other Respiratory Pathogens. *IntechOpen*. 2022 Aug 18;19.
10. Nardell EA, Keegan J, Cheney SA, Etkind SC. Airborne infection. Theoretical limits of protection achievable by building ventilation. *Am Rev Respir Dis*. 1991 Aug;144(2):302–6.
11. Bueno de Mesquita PJ, Nguyen-Van-Tam J, Killingley B, Enstone J, Lambkin-Williams R, Gilbert AS, et al. Influenza A (H3) illness and viral aerosol shedding from symptomatic naturally infected and experimentally infected cases. *Influenza Other Respir Viruses*. 2020 Jul 23;irv.12790.
12. Nardell EA. Air Disinfection for Airborne Infection Control with a Focus on COVID-19: Why Germicidal UV is Essential. *Photochem Photobiol*. 2021 May;97(3):493–7.
13. Li Y, Cheng P, Jia W. Poor ventilation worsens short-range airborne transmission of respiratory infection. *Indoor Air*. 2021 Oct;32(1):e12946.
14. Welch D, Kleiman NJ, Arden PC, Kuryla CL, Buonanno M, Ponnaiya B, et al. No Evidence of Induced Skin Cancer or Other Skin Abnormalities after Long Term (66 week) Chronic Exposure to 222-nm Far-UVC Radiation. *Photochem Photobiol*. 2022 May 25;php.13656.
15. Yamano N, Kunisada M, Kaidzu S, Sugihara K, Nishiaki-Sawada A, Ohashi H, et al. Long-term Effects of 222-nm ultraviolet radiation C Sterilizing Lamps on Mice Susceptible to Ultraviolet Radiation. *Photochem Photobiol*. 2020 Jul;96(4):853–62.
16. Fukui T, Niikura T, Oda T, Kumabe Y, Ohashi H, Sasaki M, et al. Exploratory clinical trial on the safety and bactericidal effect of 222-nm ultraviolet C irradiation in healthy humans. *PLOS ONE*. 2020 Aug 12;15(8):e0235948.
17. Buonanno M, Welch D, Brenner DJ. Exposure of Human Skin Models to KrCl Excimer Lamps: The



Impact of Optical Filtering. *Photochem Photobiol.* 2021 Jan 19;

18. Blatchley ER, Brenner DJ, Claus H, Cowan TE, Linden KG, Liu Y, et al. Far UV-C radiation: An emerging tool for pandemic control. *Crit Rev Environ Sci Technol.* 2023 Mar 19;53(6):733–53.
19. Peng Z, Miller SL, Jimenez JL. Model Evaluation of Secondary Chemistry due to Disinfection of Indoor Air with Germicidal Ultraviolet Lamps. *Environ Sci Technol Lett.* 2022 Dec 2;acs.estlett.2c00599.
20. Song DJ. Rhinovirus and childhood asthma: an update. *Korean J Pediatr.* 2016 Nov;59(11):432–9.



**Figure 1.** Images of 222 nm UV-C deployed in indoor settings, red circles around fixtures. A) childcare, B)

classroom, C) university commencement ceremony, D) school bus, E) workout room, F) healthcare, G) night club.